

Conformity Letter

Tesla Inc. 2024-11-06

3500 Deer Creek Road, Palo Alto, CA 94304 USA

Report Number: 32195916.003 Project Number: P01634821

Equipment Type: Battery Energy Storage System

Grid Support Utility Interactive Inverter

Model(s): 1850000-XX-Y (XX=00-99; Y=A-Z)

Dear Mr. Mehran Zamani,

Based on the evaluations undertaken, the model(s) of the below product have been found to comply with the requirements of the below referenced specifications.

Nationally Recognized	TUV Rheinland of North America, Inc.
Testing Laboratory (NRTL)	
NRTL Issuing Office	1279 Quarry Lane, Suite A, Pleasanton, CA 94566
Address	
Applicant Name	Tesla, Inc.
Applicant Address	3500 Deer Creek Road, Palo Alto, CA 94304, USA
Model Numbers	1850000-XX-Y consists of:
	ACPW (1092170-XX-Y or 2012170-XX-Y or
	3012170-XX-Y)
	• PVI (1538000-XX-Y)
Software/Firmware	PV Inverter MD5 Firmware Checksum:
Version	1217B43E9B859EAB26ECB10B5FBECC64
	AC Powerwall2 Firmware Checksum:
	3700B98CF516D8D8421D23891E9AD8D5
	*Site Master Controller (SMC) MD5 Firmware checksum:
	dcq8OiBXbQWYnK9UhCAjvl02/py2MZymmwAQYOn8jSc=
	Note:*Site Master Controller (SMC) is required to full
	compliance to UL1741SB
Standard(s)	ANSI/UL-9540:2020 Energy Storage Systems and
	Equipment

TUV Rheinland of North America, Inc. Pleasanton Office

1279 Quarry Lane, Suite A, Pleasanton, CA 94566

Tel: (925) 249-9123 Fax: (925) 249-9124 Web: www.us.tuv.com

TUV Rheinland of North America, Inc. North American Headquarters

12 Commerce Road Newtown, CT 06470

Tel: +1 (203) 426-0888 Fax: +1 (203) 426-4009 Mail: <u>info@tuv.com</u> Web: <u>www.tuv.com</u>

Conformity Letter

	UL 1741:2021 Edition 3: Standard for Inverters, Converters, Controllers and Interconnection System Equipment for Use with Distributed Energy Resources
	UL 1741:2021 Edition 3 Supplement SA- GRID SUPPORT UTILITY INTERACTIVE EQUIPMENT
	UL 1741:2021 Edition 3 Supplement SB, Sept. 28, 2021—GRID SUPPORT UTILITY-INTERACTIVE INVERTERS AND CONVERTERS BASED UPON IEEE 1547-2018 and IEEE 1547.1-2020
	IEEE 1547.1-2020- IEEE Standard Conformance Test Procedures for Equipment Interconnecting Distributed Energy Resources with Electric Power Systems and Associated Interfaces
	IEEE 1547a:2020 - IEEE Standard for Interconnection and Interoperability of Distributed Energy Resources with Associated Electric Power Systems Interfaces Amendment 1: To Provide More Flexibility for Adoption of Abnormal Operating Performance Category III
	Default New England Bulk System Area Settings Requirement
Source Requirements	
Document	Interoperability of Distributed Energy Resources with Associated Electric Power Systems Interfaces
	Hawaiian Electric's SRD V2.0
	Electric Rule No.21-2020 Generating Facility Interconnections
Performance Categories	Normal Operating Performance Category B
	Abnormal Operating Performance Categories III
Communication Protocol	IEEE 2030.5 protocol
Reference reports:	This document should be read together with
	32195333.001, 32195333.002, 32195333.003,
	32195333.004, US23BJDO.001 and US23BJDO.002
l	· · · · · · · · · · · · · · · · · · ·



Evaluated by:

Conformity Letter

Product Ratings

Nominal Battery Energy	13.5 kWh
System Nominal Grid Voltage	240 VAC
Maximum continuous Output Power On Grid	7.6kVA
Maximum continuous Input Power	5.8kVA
Maximum continuous Output Power Off Grid	9.6kVA
Frequency	60 Hz
Phase	2 wire + neutral + ground
Maximum Continuous Output Current On Grid	32A AC
ACPW Continuous Input Current	24 A
Maximum continuous Power Off Grid	40A AC
PV Operating DC Input Voltage range	60-550 VDC
PV Max. Input Current	13A DC
Software/Firmware version	PV Inverter MD5 Firmware Checksum:
	1217B43E9B859EAB26ECB10B5FBECC64
	AC Powerwall2 Firmware Checksum: 3700B98CF516D8D8421D23891E9AD8D5
	*Site Master Controller (SMC) MD5 Firmware checksum: dcq8OiBXbQWYnK9UhCAjvl02/py2MZymmwAQYOn8jSc=
	Note: *Site Master Controller (SMC) is required to full compliance to UL1741SB
Enclosure Type	Type 3R
Rated ambient temperature [°C]	-20°C to +50°C (Derated at 43°C to 50°C)

Thank you for the opportunity to service your product testing needs. Please do not hesitate to contact our engineering or sales team for any questions you may have.

Reviewed by:

	,
Liu Han	Howard Liu
Test Engineer	Manager, Power Electronics Segment – Americas
Email: liu.han@us.tuv.com	Email: hliu@us.tuv.com



Conformity Letter

Appendix 1: Revision History

12/17/2021-Liu Han	-Original
11/10/2022-Liu Han	-Removed 208V rating from this letter
	-Added Gateway 2.0 with Site Master Controller (SMC) MD5 Firmware checksum
	-Updated the standard to ANSI/UL-9540:2020 and UL 1741:2021 Edition 3 -Added UL 1741 SB, IEEE 1547.1 2020, IEEE 1547a 2020, IEEE 1547 2018, HECO SRD V2.0 in this letter.
11/06/2024-Liu Han	-Updated the wording from Gateway 2.0 with Site Master Controller to Site Master Controller -Added US23BJDO.001 and US23BJDO.002 as reference reports.

-----End of the Letter-----